

City of Taft Public Statement on Water Quality Assurance

The City of Taft is committed to ensuring the safety and quality of the water provided to our community. We understand that recent discussions and in-home test results shared by a resident have caused some concerns regarding the water supply. We take this opportunity to clarify the situation and reassure our citizens.

First and foremost, the City of Taft strictly adheres to the guidelines and regulations set by the Texas Commission on Environmental Quality (TCEQ). Our water supply undergoes rigorous testing on a monthly basis by certified laboratories to ensure compliance with all health and safety standards. These tests include checks for chlorine levels, as well as the presence of harmful contaminants such as E. Coli and Coliform bacteria.

We are pleased to report that the most recent test results, conducted on August 20, 2024, confirm that our water supply is safe. The chlorine levels were within the appropriate range, and there were no detections of E. Coli or Coliform in the water samples. These results demonstrate our continued commitment to maintaining a safe and reliable water supply for all residents.

For full transparency, the City of Taft posts an annual water quality report on our website. The most recent report, covering the year 2023, is available for public review at <https://www.tafttx.gov/transparency-files/557-departmental-report-december-2023-amended.pdf>. This report provides a comprehensive overview of our water quality performance, including detailed results and compliance with state and federal standards.

We encourage all residents to rely on official sources and data when evaluating the quality of the water supply. The City of Taft remains dedicated to providing safe drinking water and ensuring transparency with our community.

TCEQ Microbial Reporting Form (TCEQ-10525)

Form Instructions: www.tceq.texas.gov/databases/water/microbials/microbials_tceq10525.pdf
 (Attach 7 Copies: include all times)

Public Water System ID: TX 2050007
 (Attach 7 Copies: include all times)

Public Water System Name: CITY OF TAFT

Name: CITY OF TAFT

Address: PO BOX 416

City: TAFT

State: TEXAS

Zip Code: 78390

Phone #: 361-528-3512

PWS Email: PWD@TAFTTX.GOV

Water Utilities Laboratory - City of Corpus Christi
 13101 Leopard St
 Corpus Christi, TX 78410
 Phone: (361) 626-1200
 Email: covlab@ctctexas.com



TCEQ Laboratory ID:
 T104704386

Sample Used? Yes No

Actual Temp: 7.9

Corrected Temp: 7.9

Lab Comments: GUN B

Incubation Date and Time

Start Date and Time

End Date and Time

Analyst

Analyst

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

Lab Referred Code (LR) - Document Reason:

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

SR

I acknowledge that samples were handled appropriately and all information is accurate. Falsification of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 31.16)

Sampler Name (Print): Jessica Rodriguez

Sampler Email: JSMILO@gmail.com

Received By Sampler: Jessica Rodriguez

Received By Counter: Jerry Perkins

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM

Date and Time: 8/19/24 1:05 PM



**Corpus Christi
Water Department**

City of Corpus Christi
Water Utilities Laboratory
13101 Leopard Street
361-826-1200 Fax: 361-242-9131



Analytical Report

Client Info City of Taft (TX2050007) **Report# / Lab ID#:** AC38787 **Report Date:** 8/20/24
 P.O. Box 416 **Sample Name:** #5 122 W VERBINA
 Taft, TX 78390 **Date Received:** 08/19/2024 **Time:** 13:38
 361-528-3512 **Date Sampled:** 08/19/2024 **Time:** 11:03

Phone: 361-528-3515 **EMAIL:** agomez@taftx.gov

| Parameter | Result | Unit | Flag | RL's | Date/Time Analyzed | Method | Analyst | Analysis Comments |
|----------------------|--------|------|------|------|--------------------|------------------|---------|-------------------|
| E. coli - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Total Coliform - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |

Sample Comments:

This analytical report is respectfully submitted by the Water Utilities Laboratory. The enclosed results reflect only the sample(s) identified above. The results have been carefully reviewed and, unless otherwise indicated, meet the NELAC requirements as described by the Water Utilities Lab's QA/QC program. No part of this report shall be reproduced or transmitted in any form or by any means without the written consent of the City of Corpus Christi-Water Utilities Lab.

Respectfully Submitted,

Technical Director (or designee)



City of Corpus Christi
 Water Utilities Laboratory
 13101 Leopard Street
 361-826-1200 Fax: 361-242-9131

**Corpus Christi
 Water Department**

Analytical Report



| | | | | | | | |
|--|--|--|--|-----------------------------------|--|----------------------------------|--|
| Client Info | | | | Report# /Lab ID#: AC38786 | | Report Date: 8/20/24 | |
| City of Taft (TX2050007) P.O. Box 416 Taft, TX 78390 361-528-3512 | | | | Sample Name: #4 148 JUAREZ | | Date Received: 08/19/2024 | |
| Phone: 361-528-3515 | | | | Method | | Analyst | |
| EMAIL: agomez@taftx.gov | | | | SM 9223 B - Coli | | MONICAS | |
| | | | | SM 9223 B - Coli | | MONICAS | |
| Parameter | | | | Date/Time Analyzed | | Analysis Comments | |
| Result | | | | RL's | | | |
| ABSENT | | | | 1 | | | |
| Unit | | | | Flag | | | |
| | | | | | | | |
| Total Coliform - P/A | | | | 1 | | | |
| Sample Comments: | | | | | | | |

This analytical report is respectfully submitted by the Water Utilities Laboratory. The enclosed results reflect only the sample(s) identified above. The results have been carefully reviewed and, unless otherwise indicated, meet the NELAC requirements as described by the Water Utilities Lab's QA/QC program. No part of this report shall be reproduced or transmitted in any form or by any means without the written consent of the City of Corpus Christi-Water Utilities Lab.

Respectfully Submitted,

Technical Director (or designee)



City of Corpus Christi
 Water Utilities Laboratory
 13101 Leopard Street
 361-826-1200 Fax: 361-242-9131

**Corpus Christi
 Water Department**

Analytical Report



| Client Info | | City of Taft (TX2050007) P.O. Box 416 Taft, TX 78390 361-528-3512 | | Report# /Lab ID#: AC38785 | | Report Date: 8/20/24 | | |
|----------------------------|--------|--|------|----------------------------------|--------------------|--|---------|-------------------|
| Phone: 361-528-3515 | | EMAIL: agomez@taftx.gov | | Sample Name: #3 201 TUTT | | Date Received: 08/19/2024 Time: 13:38 | | |
| | | | | Date Sampled: 08/19/2024 | | Time: 10:43 | | |
| Parameter | Result | Unit | Flag | RL-s | Date/Time Analyzed | Method | Analyst | Analysis Comments |
| E. coli - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Total Coliform - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Sample Comments: | | | | | | | | |

This analytical report is respectfully submitted by the Water Utilities Laboratory. The enclosed results reflect only the sample(s) identified above. The results have been carefully reviewed and, unless otherwise indicated, meet the NELAC requirements as described by the Water Utilities Lab's QA/QC program. No part of this report shall be reproduced or transmitted in any form or by any means without the written consent of the City of Corpus Christi-Water Utilities Lab.

Respectfully Submitted,

Technical Director (or designee)



City of Corpus Christi
 Water Utilities Laboratory
 13101 Leopard Street
 361-826-1200 Fax: 361-242-9131

**Corpus Christi
 Water Department**

Analytical Report



| Client Info | | City of Taft (TX2050007) P.O. Box 416 Taft, TX 78390 361-528-3512 | | Report# /Lab ID#: AC38784 Sample Name: #2.502 RINCON Date Received: 08/19/2024 Time: 13:38 Date Sampled: 08/19/2024 Time: 10:31 | | Report Date: 8/20/24 | | |
|-------------------------|--------|--|------|--|--------------------|----------------------|---------|-------------------|
| Phone: | | 361-528-3515 | | EMAIL: agomez@taftx.gov | | | | |
| Parameter | Result | Unit | Flag | RL's | Date/Time Analyzed | Method | Analyst | Analysis Comments |
| E. coli - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Total Coliform - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Sample Comments: | | | | | | | | |

This analytical report is respectfully submitted by the Water Utilities Laboratory. The enclosed results reflect only the sample(s) identified above. The results have been carefully reviewed and, unless otherwise indicated, meet the NELAC requirements as described by the Water Utilities Lab's QA/QC program. No part of this report shall be reproduced or transmitted in any form or by any means without the written consent of the City of Corpus Christi-Water Utilities Lab.

Respectfully Submitted,

Technical Director (or designee)



City of Corpus Christi
 Water Utilities Laboratory
 13101 Leopard Street
 361-826-1200 Fax: 361-242-9131

**Corpus Christi
 Water Department**

Analytical Report



| Client Info | | City of Taft (TX2050007) P.O. Box 416 Taft, TX 78390 361-528-3512 | | Report# / Lab ID#: AC38783 | | Report Date: 8/20/24 | | |
|----------------------------|--------|--|------|---------------------------------------|--------------------|---|---------|-------------------|
| Phone: 361-528-3515 | | EMAIL: agomez@taftx.gov | | Sample Name: #1 225 INDUSTRIAL | | Date Received: 08/19/2024 Time: 13:38 | | |
| | | | | Date Sampled: 08/19/2024 | | Time: 10:17 | | |
| Parameter | Result | Unit | Flag | RL's | Date/Time Analyzed | Method | Analyst | Analysis Comments |
| E. coli - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Total Coliform - P/A | ABSENT | | | 1 | 8/19/24 14:24 | SM 9223 B - Coli | MONICAS | |
| Sample Comments: | | | | | | | | |

This analytical report is respectfully submitted by the Water Utilities Laboratory. The enclosed results reflect only the sample(s) identified above. The results have been carefully reviewed and, unless otherwise indicated, meet the NELAC requirements as described by the Water Utilities Lab's QA/QC program. No part of this report shall be reproduced or transmitted in any form or by any means without the written consent of the City of Corpus Christi-Water Utilities Lab.

Respectfully Submitted,

Technical Director (or designee)